



Note:

- 1.) Refer to schematic #28282-1 on units with network gateways.
- 2.) 120Vac Input Power for the Display Interface PCB can be tapped off the Control Transformer 120Vac Output secondary fuse or provided externally. For external wiring, follow all NEC guidelines.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.

NO	REVISION	DATE	BY
N	6235 consistency update	6/21/23	MJS
M	Added "Dr J9" Connection	01/14/21	JRN
L	CT consistency	10/27/21	JSG
K	Added 120V tap note	6/21/21	MJS
J	Input option note update	6/10/20	JSM
H	Add 14 Ga CPT text	2/6/18	MJS

		W132 N10611 Grant Drive Germantown, WI 53022 © TCI, 2021	
Schematic, Active Filter 150, Chassis/Type 1			
DRN. BY	RHW	DATE	4/14/14
SCALE	N/A	SIZE	A
			DWG. NO. 29070
			SHT.1 OF 1