



- Notes:
- 1) Refer to schematic #28283-1 on units with network gateways.
 - 2) OT1 is located in the exhaust area of the inductor tunnel.
 - 3) 120Vac Input Power for the Display Interface PCB can be tapped off the Control Transformer 120Vac Output secondary fuse or provided externally. For external wiring, follow all NEC guidelines.

THE INFORMATION AND DESIGNS CONTAINED IN THIS DRAWING ARE CONFIDENTIAL AND THE PROPRIETARY PROPERTY OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES. NEITHER THIS DESIGN NOR ANY INFORMATION CONTAINED IN THIS DRAWING MAY BE REPRODUCED OR DISCLOSED TO OTHERS WITHOUT THE EXPRESS WRITTEN CONSENT OF ALLIED MOTION TECHNOLOGIES INC. AND ITS SUBSIDIARIES.

NO	REVISION	DATE	BY
K	6235 Consistency Update	6/21/23	MJS
J	added J9 note to voltage feedback	1/14/22	MJS
H	5762 CT consistency	10/27/2021	JSG
F	Delta Cap/Interface 120V input tap	6/10/21	MJS
E	EC Cap update ECD 5358	8/17/20	MJS
D	ADD WIRE COLORS TO VFC	7/9/19	JHM

TOLERANCES (EXCEPT AS NOTED) DECIMAL .XX ± .03 .XXX ± .010 FRACTIONAL ± 1/32 ANGULAR ± 1°		W132 N10611 Grant Drive Germantown, WI 53022 © TCI, 2021			
Schematic, 200A/250A Active Filter, Chassis/Type 1					
DRN. BY	JJC	DATE	1/13/16	DWG. NO.	29853
SCALE	1=1	SIZE	A	SHT.1 OF 1	